



Neil LaFrance  
Inspector (print)

M 1100  
Lic #

Signature

11/28/2007  
Date

Address of Inspection: 2925 Elm St.

Dighton

ROOM #3 Living Room

SIDE	LOCATION/ SURFACE	LEAD	TYPE OF HAZARD	COMMENTS	DELEAD DATE	DELEAD METHOD
A B	Up walls	1.6	A/M L			
	Low Walls		A/M L NA			
A B	Baseboards	3.2	L NA	No Violation		
	Chair rail		A/M L NA			
	Radiator	0.6	A/M L NA			
	Floor	Cov	A/M L NA			
	Ceiling	0.1	A/M L NA			
B	Door	5.2	A/M L NA			
	Door Casing	9.9	A/M L NA			
	Door Jamb	9.9	A/M L NA			
	Threshold		A/M L NA			
C1	Door		A/M L NA			
	Door Casing	4.4	A/M L NA			
	Door Jamb	6.2	A/M L NA			
	Threshold		A/M L NA			
C2	Door	0.0	A/M L NA			
	Door Casing	2.3	A/M L NA			
	Door Jamb	6.5	A/M L NA			
	Threshold		A/M L NA			
	Door		A/M L NA			
	Door Casing		A/M L NA			
	Door Jamb		A/M L NA			
	Threshold		A/M L NA			
A	Window Sill	9.9	M/I A/M L NA			
	Win Apron	9.9	A/M L NA			
	Win Casing	8.2	A/M L NA			
	Header Stop	0.0	M/I A/M L NA			
	Int Stops	0.0	M/I A/M L NA			
	Win Int Sash	3.8	M/I A/M L NA			
	Exterior Sill	9.9	M/I L NA			
	Part Bead	NC	M/I L NA			
	Blind Stop	9.9	M/I L NA			
	Win Ext Sash	5.4	M/I L NA			
COMMENTS: M/I= Movable or Impact Surface A/M= Accessible (<5') or Mouthable L= Loose paint NA= Not Accessible for testing						

SIDE	LOCATION/ SURFACE	LEAD	TYPE OF HAZARD	COMMENTS	DELEAD DATE	DELEAD METHOD
	Window Sill	0.0	M/I A/M L NA			
	Win Apron	0.0	A/M L NA			
	Win Casing	9.9	A/M L NA			
	Header Stop	0.0	M/I A/M L NA			
D	Int Stops	0.0	M/I A/M L NA			
	Win Int Sash	NC	M/I A/M L NA	New Vinyl		
	Exterior Sill	NC	M/I L NA			
	Part Bead	NC	M/I L NA			
	Blind Stop	NC	M/I L NA			
	Win Ext Sash	NC	M/I L NA			

Page from a sample report showing detailed testing of all building components. Violations are highlighted in Yellow

	Closet Door	0.0	A/M L NA			
	Cl Casing	9.9	A/M L NA			
	Closet Jamb	9.9	A/M L NA			
C	Closet Walls	0.2	A/M L NA			
	Cl Baseboard	6.3	A/M L NA			
	Closet Pole	NC	A/M L NA			
	Closet Shelf	0.0	A/M L NA			
	Cl Supports	9.9	A/M L NA	Above 5'		
	Closet Floor	0.0	A/M L NA			
	Closet Ceiling	0.0	A/M L NA			
		Fireplace		A/M L NA		
	Mantle		A/M L NA			
			M/I A/M L NA			
			M/I A/M L NA			
			M/I A/M L NA			
			M/I A/M L NA			

EXCLUDED SURFACES: Surfaces listed in these boxes can be made intact only by a licensed deleader.

SIDE	LOCATION	MEASURE: LOOSE PAINT (MORE THAN 288 SQ. IN.)	DELEAD DATE	DELEAD METHOD

SIDE	LOCATION	MEASURE: LOOSE PAINT (MORE THAN 288 SQ. IN.)	DELEAD DATE	DELEAD METHOD